

GERMAN TOWNSHIP FIRE-RESCUE

PROFESSIONAL VOLUNTEERS FAITHFULLY SERVING

8400 Saint Wendel Road

Evansville, IN 47720

Voice 812-963-9077

Fax 812-963-5622

Email germanfdhq@insightbb.com

Internet www.germanfiredept.org

To: All Members

From: Captain Phillip Craig

Date: 7-8-08

Re: Cascade Fill Operation Procedures

Standing Order: 2002-010

*** Always wear hearing protection during compressor operation ***

1. Check oil level in compressor, and log start hours in compressor log book.
2. Check Carbon Monoxide Meter on wall to assure a Zero reading.
3. Get the 35' gray fill hose marked " cascade fill hose " next to the compressor.
4. Attach brass end to the compressor on the right side of the control panel ****Hand tight only, do not use a wrench****
5. Attach the other end to cascade fitting on the upper right side of bottle #4, you may have to use the wrench located in the cascade compartment to tighten this fitting if is leaking after compressor is turned on.
6. Open all bottles and then open fill valve on cascade.
7. Open Unregulated Valve on compressor panel.
8. Turn compressor to "ON" position.
9. When cascade is finished filling, log all info in compressor log book

BROTHER FIRST - DUTY ALWAYS